



GREEN STAR

HEALTHCARE V1

**GREENHOUSE GAS EMISSIONS
CALCULATOR GUIDE**

JUNE 2009

TABLE OF CONTENTS

1.0	INTRODUCTION_____	3
2.0	GLOSSARY_____	3
3.0	REQUIREMENTS FOR SIMULATION_____	3
3.1	Simulation software requirements_____	4
3.2	Overview of the simulation of the Proposed and Reference Building performance_____	4
3.3	Simulation guidelines for each parameter for the Proposed and Reference Building_____	5
4.0	HOW THE POINTS ARE CALCULATED_____	8
5.0	DOCUMENTATION REQUIREMENTS FOR A GREEN STAR SUBMISSION_____	11
6.0	REFERENCES_____	14
APPENDIX A – INTERNAL HEAT LOAD AND OCCUPANCY AND OPERATIONAL PROFILES_____		15
APPENDIX B – LIFT ENERGY CONSUMPTION METHODOLOGY_____		29
APPENDIX C – GREENHOUSE GAS EMISSIONS FACTORS_____		32

Tool Version	Revision	Date Issued
Green Star – Healthcare v1 Release	A	June 2009

1.0 – Introduction

This document explains how the greenhouse gas emissions of a proposed healthcare facility are assessed for purposes of the Ene-1 'Greenhouse Gas Emissions' credit. It explains how the energy consumption of the 'Proposed Building', along with a 'Reference Building' needs to be modelled using dynamic simulation. It then explains how the results of this modelling are used to determine the greenhouse gas emissions of the Proposed and the Benchmark Buildings (see Glossary) and hence, the number of points awarded.

Projects are awarded points for each 5% reduction in emissions on the Benchmark building (the Benchmark building is 10% more efficient than the 'Reference building').

This method minimises the additional work required to be undertaken by design teams, whilst maximising the accuracy of the calculation method. To achieve this aim, where possible, the modelling methodology described in this document is identical to modelling methodology required for demonstrating compliance with Section J of the Building Code of Australia (BCA) using the JV3 verification methodology.

Where the GBCA received feedback that the JV3 methodology was not appropriate for that building type, or where particular energy saving measures were not being recognised by the methodology, we have altered the methodology.

Note: Throughout this document, wherever the BCA is referenced, the version applicable to the project is the BCA 2008, or later. When quoted, the clause numbers are from BCA 2008 Volume 1.

2.0 – Glossary

Proposed Building: The building, as designed and modelled by the project team.

Reference Building: A hypothetical building based predominantly on the BCA Section J Deemed-to-Satisfy provisions.

Benchmark Building: A building modelled to be 10% more efficient over the Reference Building. Points are awarded where the emissions from the Proposed Building are lower than the Benchmark Building's emissions.

3.0 – Requirements for specification

The Green Star – Healthcare v1 Greenhouse Gas Emissions Calculator requires the energy consumption from the Proposed Building along with a 'Reference Building' to be calculated using simulation software. This chapter provides details on what simulation software should be used, and how each component of the Proposed and Reference Buildings should be modelled.

3.1 – Simulation software requirements

As with the BCA Specification JV, the energy consumption from the Proposed and Reference Building 'must be calculated using a thermal calculation method that complies with the ABCB Protocol for Energy Analysis Software 2006.1' (BCA Specification JV, clause 2.(f)).

3.2 – Overview of the simulation of the Proposed and Reference Building performance

The annual energy consumption from the **Proposed Building** should be modelled in accordance with the BCA Section JV3 verification methodology. The exceptions to this include the following:

- The climate file – where a climate file as described in Table 1 is used;
- The occupancy and operational profiles – where those provided in Appendix B must be used for both the Proposed Building and the Reference Building. However, if the project team wishes to use alternative profiles, they must submit a Credit Interpretation Request (CIR). Please note that if alternative profiles are approved, the same profiles must still be used for the Proposed and Reference buildings;
- The percentage of electricity generated on-site from sources that do not emit greenhouse gases (such as solar and wind) where 100% of the energy generated may be used to reduce the calculated annual energy consumption of the building. This is a change from BCA 2008 Specification JV, clause 2 (e) which limits the reduction to 50% of the energy generated on-site. As with the BCA, Co-generation can also be modelled at 100%.

All parameters used in the modelling the **Proposed Building** should be consistent with the design documents.

The modelling requirements for the **Reference Building** are also predominantly in accordance with the BCA JV3 verification methodology. As described in the BCA JV3 verification methodology, the Proposed Building and Reference Building must be calculated with the same calculation method (as defined above); physical model; internal heat gains; occupancy and operational profiles; servicing requirements; HVAC zoning; and in the same location with the same environmental conditions. The building envelope performance, HVAC plant performance and lighting lamp power or illumination power density must be based on the BCA Deemed-to-Satisfy criteria. The exceptions to using the JV3 verification methodology for the Reference Building include the following:

- The Reference Building HVAC system type must be the system type given in ASHRAE 90.1:2007, Appendix G, Section G3.1.1. However, as noted above, the HVAC plant performance parameters must be in accordance with BCA.

3.3 – Simulation guidelines for each parameter for the Proposed and Reference Building

Table 1: Modelling requirements for calculating the Proposed and Reference Building energy consumption

No.	Proposed Building modelling requirements	Reference Building modelling requirements
1. Thermal calculation method	As BCA Specification JV, clause 2.(f), a thermal calculation method that complies with the ABCB Protocol for Energy Analysis Software 2006.1'	As Proposed Building (as BCA Section J, JV3 (b)(ii)(A))
2. Location (selection of climate file)	A Test Reference Year (TRY) if the building location is within 50km of a TRY location; or In the absence of local TRY weather data, an actual year of recorded weather data from a location within 50km of the building location; or In the absence of TRY or actual weather data within 50km, interpolated data based upon 3 points within 250km of the building location. Please contact the Green Building Council of Australia for approval of alternative climate files if the project cannot comply with any of the above options.	As Proposed Building (as BCA Section J, JV3 (b) (ii) (B))
3. Adjacent structures and features	As BCA Section J, JV3 (b) (ii) (C)), overshadowing from the surrounding environment must be taken into account in the model.	As Proposed Building (as BCA Section J, JV3 (b) (ii) (C))
4.Environmental conditions	As BCA Section J, JV3 (b) (ii) (D))	As Proposed Building (as BCA Section J, JV3 (b) (ii) (D))
5.Orientation	The representation of Proposed Building orientation shall be consistent with the design documents.	As Proposed Building (as BCA Section J, JV3 (b) (ii) (D))
6. Geometric model	The representation of Proposed Building's geometry shall be consistent with the design documents.	As Proposed Building (as BCA Section J, JV3 (b) (ii) (F, G, H, I, J, K, L, M, N, O))
7. Building envelope	The simulation of the Proposed Building envelope shall be consistent with the design documents. Note: Manual fenestration shading devices such as blinds or shades shall not be modelled.	BCA Deemed-to-Satisfy provisions (see BCA Section J, JV3 (b) (i) (A))

No.	Proposed Building modelling requirements	Reference Building modelling requirements
8. Internal heat gains	The internal heat gains from occupants, lighting and equipment given in Appendix B must be used.	As Proposed Building. (BCA Section J, JV3 (b) (ii) (S))
9. Occupancy, lighting and equipment profiles.	<p>The occupancy and operational profiles given in Appendix B must be used.</p> <p>If the project team wishes to use alternative profiles, they must submit a Credit Interpretation Request (CIR). Please note that if alternative profiles are approved, the same profiles must still be used for the Proposed and Reference Buildings.</p>	As Proposed Building. (BCA Section J, JV3 (b) (ii) (U))
10. HVAC zones	The simulation of the Proposed HVAC zones shall be consistent with the design documents.	As Proposed Building. (BCA Section J, JV3 (b) (ii) (T))
11. HVAC system	As BCA Specification JV, clause 2 (a)	<p>The HVAC system type must be as specified in ASHRAE Standard 90.1, Appendix G :</p> <p>"The HVAC system type(s) in the [Reference Building design] shall be of the type and description specified in Section G3.1.1.</p> <p>All the deemed-to-satisfy requirements of J5 must be complied with for the Reference Building system type, and must modelled in accordance with Specification JV, clause 2 (a).</p>
12. Artificial internal lighting	As BCA Specification JV, clause 2.(b).	<p>Maximum lamp power or maximum illumination power as specified in the Deemed-to-Satisfy Provisions, without any occupancy or daylight sensors; corridor timers; dimming systems; or dynamic lighting control devices (BCA Section J, JV3 (b) (i) (A & C)).</p> <p>Required lighting levels as Proposed Building. (BCA Section J, JV3 (b) (ii) (R))</p>
13. Domestic hot water systems	As BCA Specification JV, clause 2.(d)	As BCA Section J, JV3 (b) (ii) (W)).
14. On-site energy generation from sources that do not emit greenhouse gases such as solar and wind	<p>100% of the energy generated on-site from sources that do not emit greenhouse gases, such as solar and wind may be used to reduce the calculated annual energy consumption of the building.</p> <p>The modelling methodology to be used must be Proposed by the design team in the form of a CIR.</p>	None

No.	Proposed Building modelling requirements	Reference Building modelling requirements
15. Lifts	Modelled using the modified Draft ISO standard calculation methodology detailed in Appendix A	Modelled using the modified Draft ISO standard calculation methodology detailed in Appendix A
16. Other energy consumption	<p>Any other energy consumed on site for base building facilities, such as a water recycling treatment plant, or escalators and travelators, should be calculated by the design team and included.</p> <p>All assumptions used in the calculation must be provided in the documentation and justified.</p>	None
17. Internal equipment/ process load	<p>The energy consumed by medical/office equipment directly, is not included in the assessment. This energy consumption is related to the function of the building rather than the physical attributes of the building fabric and services which is being assessed in this credit.</p> <p>Please note however, that approximated internal heat loads resulting from equipment use must be included in the simulation of the HVAC energy consumption as described points 8 and 9 of this table.</p>	As Proposed Building

4.0 – How the points are calculated

Up to twenty points are awarded where it is demonstrated that the building's predicted greenhouse gas emissions have been reduced below that of the **'Benchmark Building'**. The Benchmark building is 10% more efficient than the Reference Building.

The number of points is established as follows:

1. The design team enters the annual energy consumption from the Proposed Building and the Reference Building into the Green Star – Greenhouse Gas Calculator (the calculator) as shown in below:

Select the energy source for each end use.

Enter the annual energy consumption for the Proposed and Reference Buildings in terms of kWh of electricity and MJ of fuel.

Energy consumption and generation (user input required in this section)			PROPOSED BUILDING		REFERENCE BUILDING	
			Annual Energy Consumption (kWh/yr electricity or MJ/yr fuel)	TOTAL Annual Greenhouse Gas Emissions (kgCO ₂ -e/yr)	Annual Energy Consumption (kWh/yr electricity or MJ/yr fuel)	TOTAL Annual Greenhouse Gas Emissions (kgCO ₂ -e/yr)
Energy consumption		Energy source		0		0
HVAC - Heating		Natural gas		0		0
HVAC - Cooling		Electricity		0		0
HVAC - Pumps and fans		Electricity		0		0
Co-generation and Tri-generation		Electricity		0		0
Lighting		Select Fuel Type Electricity		0		0
Domestic Hot Water		Natural gas		0		0
Mechanical exhaust		LPG Diesel Coal		0		0
Lifts		Biomass Liquid biofuels		0		0
Other (1)	<Enter description of use>	Electricity		0		0
Other (2)	<Enter description of use>	Electricity		0		0
Other (3)	<Enter description of use>	Electricity		0		0
TOTALS				0		0
Electricity generation						
From Renewable Energy						
From Co-generation and Tri-generation (kWh/yr)						

Figure 1: Energy consumption and generation section of the excel tool

Enter electricity generated on-site from co-generation, tri-generation and renewable sources.

The emissions by end use are presented here for the Proposed and Reference buildings.

2. The calculator multiplies the energy consumption by appropriate GHG emissions factors to determine the annual GHG emissions from both the Proposed and Reference Building. GHG emissions factors used are from the National Greenhouse Accounts (NGA) Factors, Department of Climate Change (DCC), current at the time of release. See Appendix B for a full description of the emissions factors used;
3. The calculator then multiplies the GHG emission from the Reference Building by 90% to determine the Benchmark building emissions.

$$\text{Benchmark building GHG emissions} = \text{Reference Building GHG emissions (as calculated through simulation)} \times 90\%$$

The calculator then compares the emissions from the Proposed and Benchmark building as follows to determine the percentage reduction in GHG emissions.

$$\text{Percentage reduction in greenhouse gas emissions} = \frac{(\text{Reference Building GHG emissions} - \text{Benchmark building GHG emissions})}{\text{Benchmark building GHG emissions}}$$

For each 5% improvement on the Benchmark building, one point is awarded, up to a maximum of 20 for a 100% reduction.

Percentage reduction in Greenhouse Gas Emissions (%)	Points Awarded
0	0
5	1
10	2
15	3
20	4
25	5
30	6
35	7
40	8
45	9
50	10
55	11
60	12
65	13
70	14
75	15
80	16
85	17
90	18
95	19
100 (Zero net operating emissions)	20

These figures followed by the number of points and whether or not the building meets the conditional requirement, are then presented as shown in Figure 2 below.

Results	
	TOTAL Annual Greenhouse Gas Emissions (kgCO₂-e/yr)
BENCHMARK greenhouse gas emissions (10% improvement on the reference building emissions)	0
Greenhouse gas emissions savings (Difference in greenhouse gas emissions between benchmark and proposed building (kgCO ₂ /yr))	-
	Percent reduction in TOTAL greenhouse gas emissions
Percent reduction in greenhouse gas emissions compared to the benchmark.	-
Is the conditional requirement met?	Yes
Points Achieved	0

Figure 2: Results section of the excel tool.

5.0 – Documentation guidelines for a Green Star submission

The energy modelling report must be prepared in accordance with the Green Star Healthcare v1 Greenhouse Gas Emissions Guide and must clearly:

- Identify all default values used (e.g. occupant density);
- Identify all of the design-driven inputs referencing drawings, schedules and specifications. Whenever assumptions are used, they must be justified and conservative; and
- Correspond to the design.

All other aspects of the building must have been modelled correctly, with no significant compromises made. If these requirements are not met, then the reasons for this will need to be adequately justified.

The Energy Modelling Report must include as a minimum the information detailed below:

1) Executive Summary

The executive summary must include at a minimum:

- An overview of the Proposed Building including:
 - a description of all systems installed and their environmental performance;
 - a description of energy saving features; and
 - a brief description of the control strategy of the building's systems.
- A brief overview of the main attributes of the Reference Building;
- A summary of energy consumption for the proposed and Reference Buildings by end use and fuel type.

2) Simulation package and model description

The simulation and model brief must include at a minimum:

- Confirmation that the simulation package complies with one of the following standards:
 - BESTEST (US NREL, 2005); or
 - The European Union draft standard EN13791 July 2000; or
 - Be certified in accordance with ANSI/ASHRAE Standard 140-2001.
- Confirmation that the building performance is analysed on an hourly basis for a full year;
- Details of the weather data file selected (type of data and weather station location);
- A description of the simulation package's accuracy at representing:
 - The proposed and reference HVAC systems;
 - The HVAC controls which are to be used;
 - Glazing on the building – whether the model represents glazing as only a U-value and shading coefficient;
 - The performance curves and sizes for plant items; and
 - The daylighting effects and the operation of daylight controls.
- A description of any compromises made in regards to the modelling of the building and what effect they have on the results.

3) Schedule of inputs

A schedule of inputs should be provided for both the reference and Proposed Buildings, and should include, but not be limited to:

- Area schedule indicating the occupant density, internal loads for equipment, internal loads for people and profile chosen for each space, or typical space;
- Building fabric;
 - Building form, including any simplifications and their effect;
 - Orientation;
 - Insulation;
 - Glazing;
 - Shading (window shading and external building fabric) and overshadowing;
 - Window and spandrel sizes; and
 - Infiltration.
- HVAC;
 - Heating system selection, including any reheat limits;
 - Cooling system selection; and
 - Air handling and ventilation system description, including air flow rates, system static pressure, fan maximum total motor shaft power and fan motor power to air flow rate ratio.
- Lighting (for each space, or typical space);
 - Average lighting levels;
 - Light power density; and
 - Lighting controls;
- Hot Water;
- Mechanical ventilation, lifts and other amenities; and
- On-site electricity generation.

4) Reference and Proposed Building energy simulation details and results

The following must be provided for both the Reference Building and the Proposed Building.

- HVAC energy systems;
 - Space Type Breakdown, including:
 - Details of the area (m²), space type and profile selection for each area of the building.
 - Confirmation that the lighting power density, equipment power density, occupancy load and occupancy and operational profiles were used as per the Green Star – Healthcare Greenhouse Gas Emissions Calculator Guide for each space, or typical space type.
 - HVAC System: Detailing, and including supporting documentation of, how the following aspects of the HVAC system have been modelled/represented in the model:
 - HVAC system design;
 - Air-conditioning zones;
 - Chiller plant, including the chiller plant size and details on the efficiency curves that have been used and details on how the chiller data is relevant to the intended condenser water temperature controls;
 - Boiler plant;
 - Supply air and exhaust fans, including details on how the index run pressure drops have been calculated and modelled and including:
 - Fan Maximum Total Motor Shaft Power
 - Maximum Fan Motor Power to Air Flow Rate Ratio
 - System static pressure

- Cooling tower fans; and
- Cooling tower and condenser water pumping.
- Building Environmental Control Strategy including:
 - A clear description of the overall control systems. The description must include an analysis of the benefits and conflicts of having these control strategies working alongside each other;
 - Control(s) of any building envelope elements (glazing, shading devices, etc);
 - Lighting/daylighting interaction(s); and
 - Air / plant side HVAC control(s); detailing, and including supporting documentation describing how the following aspects of the HVAC controls have been modelled/represented in the model:
 - Outside air flow;
 - Economy cycle;
 - Primary duct temperature control, including details on how design temperatures and setpoints have been modelled;
 - Airflow control;
 - Minimum turndown;
 - Chiller staging; and
 - Temperature control bands.
- A/C Pumping: Detailing, and including supporting documentation describing how the following have been calculated:
 - Pump maximum motor shaft power; and
 - Chilled water energy efficiency ratio for the selected cooling equipment (refrigerant chillers or packaged equipment);
 - Type of equipment used for each area;
 - Energy efficiency ratio for the selected cooling equipment (refrigerant chillers or packaged equipment).
 - Heating hot water thermal efficiency of the selected water heater
 - Rated capacity
 - Fuel type
 - Thermal efficiency of the selected water heater
- HVAC simulation outputs.
- Lighting: Detailing the energy use calculations, and including supporting documentation for each space, or typical space, including:
 - The lighting power density;
 - The lighting controls systems and their energy use; and
 - The operational profiles used.
- Hot Water: Detailing the energy use calculations for all hot water systems, and including supporting documentation such as system efficiency and fuel type.
- Mechanical ventilation, lifts and other amenities: Detailing the energy use calculations, and including supporting documentation for:
 - Lifts including lift motor rating and stand-by power;
 - Car park ventilation; and
 - Any other energy use such as travelators, escalators, water reuse systems, etc.
- Electricity Generation Detailing, and including supporting documentation describing how the following has been modelled including all operational assumptions (e.g. solar/wind and other fuel resources):
 - Renewable energy systems; and
 - Co-generation, tri-generation systems.

5.0 – References

- Australian Building Codes Board (ABCB) (2008), Volume One Class 2-9 Buildings, BCA 2008, Australian Building Codes Board, Australia.
- Australian Building Codes Board (ABCB) (2006), Protocol for Energy Analysis Software 2006.1, <http://www.abcb.gov.au/index.cfm?objectid=6928102C-F27E-4834-0B94E42A0568F11B>, accessed June, 2009.
- American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) (2007), Energy Standard for Buildings Except Low-Rise Residential Buildings (SI Edition), ASHRAE Standard 90.1-2007 SI Edition, <http://www.ashrae.org/technology/page/548>, accessed June, 2009.
- Barney, G. (2007), 'Energy efficiency of lifts – measurement, conformance, modelling, prediction and simulation' (presentation), www.cibseliftsgroup.org/CIBSE/papers/Barney-on-energy%20efficiency%20of%20lifts.pdf, accessed June, 2009.
- Department of Climate Change (DCC), The National Greenhouse Accounts (NGA) Factors, <http://www.climatechange.gov.au/workbook>, accessed June, 2009.
- International Organization for Standardization (ISO) (2008), Energy performance of lifts and escalators - Part 1: Energy measurement and conformance, ISO/DIS 25745-1: 2008 (Draft standard - currently under development), International Organization for Standardization, Geneva.
- New South Wales Health (NSW Health) (2007), Technical Series 11: Engineering Services and Sustainable Development Guidelines, www.healthfacilityguidelines.com.au, accessed June 2008
- Standards Australia (SA) (2002), AS 1668.2—2002, Australian Standard, The use of ventilation and airconditioning in buildings, Part 2: Ventilation design for indoor air contaminant control (excluding requirements for the health aspects of tobacco smoke exposure).

Appendix A – Internal heat load, occupancy and operational profiles

This appendix contains the internal heat loads and occupancy and operational profiles which need to be applied to each zone within the healthcare facility under assessment. The same heat loads and occupancy and operational profiles should be used for both the Proposed and Reference Buildings.

Note: When calculating the energy consumption of the lighting of the facility, the lighting profile in this Appendix should be used in conjunction with the lighting densities as per the lighting specification.

Maximum occupancy, lighting and equipment heat loads

The maximum occupancy, lighting and equipment heat load figures to be used are those required for use are given in Table 2 below. These heat loads should be used in combination with the occupancy and operational profiles given below.

Table 2: Maximum occupancy, lighting and equipment loads

	For all space types excluding operating suites	Operating suites only
Occupancy	The occupancy densities that must be used are those stipulated in the Australian Standard, AS 1668.2—2002, (SA, 2002).	
Metabolic rate	The metabolic rates that must be used are as required for JV3 (75W sensible and 55W latent).	
Lighting	The representation of Proposed Building orientation shall be consistent with the design documents.	25W/m ²
Equipment	As required for JV3, the equipment loads are those give in Table 2h: Internal heat gains for appliances and equipment.	40W/m ²

Occupancy and operational profiles

The profiles, which must be used in combination with the heat load figures given in Table 2, have been developed with reference to the profiles given in BCA Specification J, the profiles given in the NSW Health publication, Engineering Services and Sustainable Development Guidelines, TS11 v2.0 (NSW Health, 2007) and with input from industry. These profiles provide typical hours of operation for the majority of healthcare space types.

The simulator should choose the profile most appropriate profile for each space within the healthcare facility. If none of the profiles provided give a reasonable estimation of the expected hours of operation of a particular space, the design team should submit a Credit Interpretation Request (CIR) to the GBCA.

The profiles provided include:

1. General areas - 12 hours;
2. General areas - 24 hours;
3. Operating room suite – 12 hours;
4. Operating room suite – 24 hours;
5. Emergency;
6. Wards;
7. Kitchen;
8. Transitory spaces – 12 hours;
9. Transitory spaces – 24 hours; and
10. Back of house.

A description of each profile, along with examples of typical spaces which would use it, follows.

General areas - 12 hour

The 'General Areas – 12 hour' profile should be used for all:

- Areas that operate during the day only (excluding 12 – hour operating suites, corridors, kitchens or back-of house areas; separate profiles have been specifically developed specifically for those space types).

This profile is typical of the operation of a large number of small healthcare facility spaces. It may also be appropriate for a number of hospital spaces. This profile can be applied to spaces that operate for five or seven days of the week.

Examples of space types which would use this profile for five days of the week include office areas, outpatients, waiting areas, consulting areas, diagnostic areas, medical records, pathology, pharmacy, auditoriums and seminar rooms.

Examples of space types which would use this profile for seven days of the week include cafes and the hospital main receptions.

Table 3: General areas - 12 hour

Time	Occupancy (%)	Artificial lighting (%)	Appliances and equipment (%)	Plant Operation
12am – 1am	0%	10%	10%	Off
1am – 2am	0%	10%	10%	Off
2am – 3am	0%	10%	10%	Off
3am – 4am	0%	10%	10%	Off
4am – 5am	0%	10%	10%	Off
5am – 6am	0%	10%	10%	Off
6am – 7am	0%	10%	15%	Off
7am – 8am	15%	40%	25%	On
8am – 9am	50%	80%	70%	On
9am – 10am	70%	100%	100%	On
10am – 11am	70%	100%	100%	On
11am – 12pm	70%	100%	100%	On
12pm – 1pm	70%	100%	100%	On
1pm – 2pm	70%	100%	100%	On
2pm – 3pm	70%	100%	100%	On
3pm – 4pm	70%	100%	100%	On
4pm – 5pm	70%	100%	100%	On
5pm – 6pm	50%	80%	60%	On
6pm – 7pm	15%	60%	25%	On
7pm – 8pm	5%	40%	15%	Off
8pm – 9pm	5%	20%	15%	Off
9pm – 10pm	0%	10%	10%	Off
10pm – 11pm	0%	10%	10%	Off
11pm – 12am	0%	10%	10%	Off

General areas - 24 hour

The 'General Areas – 24 hour' profiles should be used for:

- Areas that are conditioned for 24 hours a day, seven days a week and that have peak operation for five days of the week and reduced operation over night and at the weekends.

Two profiles are provided; one that should be used for the weekdays and the other that should be used for the weekends.

These profiles are typical of the operation of a large number of hospitals space types. They may also be appropriate for some spaces in smaller healthcare facilities. Examples of spaces that would use these profiles include medical imaging, recovery, central sterilising services department, pathology and pharmacy areas, within a hospital.

Table 4: General areas - 24 hour (weekdays)

Time	Occupancy (%)	Artificial lighting (%)	Appliances and equipment (%)	Plant Operation
12am – 1am	10%	10%	10%	On
1am – 2am	10%	10%	10%	On
2am – 3am	10%	10%	10%	On
3am – 4am	10%	10%	10%	On
4am – 5am	10%	10%	10%	On
5am – 6am	10%	10%	10%	On
6am – 7am	10%	10%	10%	On
7am – 8am	15%	40%	25%	On
8am – 9am	60%	80%	70%	On
9am – 10am	70%	100%	100%	On
10am – 11am	70%	100%	100%	On
11am – 12pm	70%	100%	100%	On
12pm – 1pm	70%	100%	100%	On
1pm – 2pm	70%	100%	100%	On
2pm – 3pm	70%	100%	100%	On
3pm – 4pm	70%	100%	100%	On
4pm – 5pm	70%	100%	100%	On
5pm – 6pm	50%	70%	70%	On
6pm – 7pm	15%	30%	30%	On
7pm – 8pm	10%	10%	10%	On
8pm – 9pm	10%	10%	10%	On
9pm – 10pm	10%	10%	10%	On
10pm – 11pm	10%	10%	10%	On
11pm – 12am	10%	10%	10%	On

Table 5: General areas - 24 hour (weekends)

Time	Occupancy (%)	Artificial lighting (%)	Appliances and equipment (%)	Plant Operation
12am – 1am	10%	10%	10%	On
1am – 2am	10%	10%	10%	On
2am – 3am	10%	10%	10%	On
3am – 4am	10%	10%	10%	On
4am – 5am	10%	10%	10%	On
5am – 6am	10%	10%	10%	On
6am – 7am	10%	10%	10%	On
7am – 8am	10%	10%	10%	On
8am – 9am	10%	10%	10%	On
9am – 10am	10%	10%	10%	On
10am – 11am	10%	10%	10%	On
11am – 12pm	10%	10%	10%	On
12pm – 1pm	10%	10%	10%	On
1pm – 2pm	10%	10%	10%	On
2pm – 3pm	10%	10%	10%	On
3pm – 4pm	10%	10%	10%	On
4pm – 5pm	10%	10%	10%	On
5pm – 6pm	10%	10%	10%	On
6pm – 7pm	10%	10%	10%	On
7pm – 8pm	10%	10%	10%	On
8pm – 9pm	10%	10%	10%	On
9pm – 10pm	10%	10%	10%	On
10pm – 11pm	10%	10%	10%	On
11pm – 12am	10%	10%	10%	On

Operating room suite - 12 hours

The 'Operating room suite – 12 hours' profile should be used for:

- Operating suite areas that will predominantly operate five days per week (Mon-Fri) for 12 hours per day. While it might be expected that the operating suite may be used on weekends, this is not its expected primary use pattern.

Examples of spaces that would use this profile include general and endoscopy operating suite areas.

Table 6: Operating room suite - 12 hours

Time	Occupancy (%)	Artificial lighting (%)	Appliances and equipment (%)	Plant Operation
12am – 1am	0%	0%	15%	Off
1am – 2am	0%	0%	15%	Off
2am – 3am	0%	0%	15%	Off
3am – 4am	0%	0%	15%	Off
4am – 5am	0%	0%	15%	Off
5am – 6am	0%	0%	15%	Off
6am – 7am	30%	25%	25%	On
7am – 8am	30%	25%	25%	On
8am – 9am	50%	50%	50%	On
9am – 10am	60%	100%	100%	On
10am – 11am	70%	100%	100%	On
11am – 12pm	70%	100%	100%	On
12pm – 1pm	70%	100%	100%	On
1pm – 2pm	70%	100%	100%	On
2pm – 3pm	70%	100%	100%	On
3pm – 4pm	60%	100%	100%	On
4pm – 5pm	50%	50%	50%	On
5pm – 6pm	30%	25%	25%	On
6pm – 7pm	0%	0%	15%	Off
7pm – 8pm	0%	0%	15%	Off
8pm – 9pm	0%	0%	15%	Off
9pm – 10pm	0%	0%	15%	Off
10pm – 11pm	0%	0%	15%	Off
11pm – 12am	0%	0%	15%	Off

Operating room suite – 24 hours

The 'Operating room suite – 24 hours' profile should be used for:

- Operating suite areas that are intended to be conditioned for 24 hours per day, seven days per week.

A typical area that would use this profile is an operating suite in the emergency department of a hospital.

Table 7: Operating room suite - 24 hours

Time	Occupancy (%)	Artificial lighting (%)	Appliances and equipment (%)	Plant Operation
12am – 1am	15%	15%	15%	On
1am – 2am	15%	15%	15%	On
2am – 3am	15%	15%	15%	On
3am – 4am	15%	15%	15%	On
4am – 5am	15%	15%	15%	On
5am – 6am	20%	15%	15%	On
6am – 7am	25%	25%	25%	On
7am – 8am	30%	25%	25%	On
8am – 9am	50%	50%	50%	On
9am – 10am	60%	100%	100%	On
10am – 11am	70%	100%	100%	On
11am – 12pm	70%	100%	100%	On
12pm – 1pm	70%	100%	100%	On
1pm – 2pm	70%	100%	100%	On
2pm – 3pm	70%	100%	100%	On
3pm – 4pm	60%	100%	100%	On
4pm – 5pm	50%	50%	50%	On
5pm – 6pm	30%	25%	25%	On
6pm – 7pm	25%	20%	20%	On
7pm – 8pm	20%	15%	15%	On
8pm – 9pm	15%	15%	15%	On
9pm – 10pm	15%	15%	15%	On
10pm – 11pm	15%	15%	15%	On
11pm – 12am	15%	15%	15%	On

Emergency

The 'Emergency' profile should be used for:

- All emergency department areas (except for the emergency operating room suites, which should use the 'Operating suite - 24 hour').

All emergency areas are assumed to be conditioned for 24 hours per day, seven days per week.

Two profiles are provided; one that should be used for the off-peak period between Sunday and Thursday and the other that should be used for the peak period of Friday and Saturday.

Table 8: Emergency – off-peak (Sunday - Thursday)

Time	Occupancy (%)	Artificial lighting (%)	Appliances and equipment (%)	Plant Operation
12am – 1am	10%	100%	50%	On
1am – 2am	10%	100%	50%	On
2am – 3am	10%	100%	50%	On
3am – 4am	10%	100%	50%	On
4am – 5am	10%	100%	50%	On
5am – 6am	10%	100%	50%	On
6am – 7am	10%	100%	50%	On
7am – 8am	20%	100%	55%	On
8am – 9am	30%	100%	60%	On
9am – 10am	40%	100%	70%	On
10am – 11am	50%	100%	80%	On
11am – 12pm	50%	100%	80%	On
12pm – 1pm	50%	100%	80%	On
1pm – 2pm	50%	100%	80%	On
2pm – 3pm	50%	100%	80%	On
3pm – 4pm	50%	100%	80%	On
4pm – 5pm	40%	100%	70%	On
5pm – 6pm	30%	100%	60%	On
6pm – 7pm	20%	100%	55%	On
7pm – 8pm	10%	100%	50%	On
8pm – 9pm	10%	100%	50%	On
9pm – 10pm	10%	100%	50%	On
10pm – 11pm	10%	100%	50%	On
11pm – 12am	10%	100%	50%	On

Table 9: Emergency - peak (Friday and Saturday)

Time	Occupancy (%)	Artificial lighting (%)	Appliances and equipment (%)	Plant Operation
12am – 1am	10%	100%	50%	On
1am – 2am	10%	100%	50%	On
2am – 3am	10%	100%	50%	On
3am – 4am	10%	100%	50%	On
4am – 5am	10%	100%	50%	On
5am – 6am	10%	100%	50%	On
6am – 7am	10%	100%	50%	On
7am – 8am	20%	100%	55%	On
8am – 9am	30%	100%	60%	On
9am – 10am	40%	100%	75%	On
10am – 11am	50%	100%	80%	On
11am – 12pm	60%	100%	80%	On
12pm – 1pm	60%	100%	80%	On
1pm – 2pm	60%	100%	80%	On
2pm – 3pm	60%	100%	80%	On
3pm – 4pm	60%	100%	80%	On
4pm – 5pm	70%	100%	85%	On
5pm – 6pm	80%	100%	90%	On
6pm – 7pm	90%	100%	95%	On
7pm – 8pm	100%	100%	100%	On
8pm – 9pm	100%	100%	100%	On
9pm – 10pm	100%	100%	100%	On
10pm – 11pm	100%	100%	100%	On
11pm – 12am	100%	100%	100%	On

Wards

The 'Wards' profile should be used for:

- All areas that are for the care and recovery of patients (in beds) which are occupied 24 hours per day, seven days per week.

Areas that are expected to use this profile are all inpatient wards, maternity wards and critical care areas. It should also be used for the ward offices and nurse's stations.

Table 10: Wards

Time	Occupancy (%)	Artificial lighting (%)	Appliances and equipment (%)	Plant Operation
12am – 1am	50%	10%	70%	On
1am – 2am	50%	10%	70%	On
2am – 3am	50%	10%	70%	On
3am – 4am	50%	10%	70%	On
4am – 5am	50%	10%	70%	On
5am – 6am	50%	25%	70%	On
6am – 7am	50%	25%	70%	On
7am – 8am	60%	80%	70%	On
8am – 9am	60%	100%	70%	On
9am – 10am	70%	100%	70%	On
10am – 11am	70%	100%	70%	On
11am – 12pm	70%	100%	70%	On
12pm – 1pm	70%	100%	70%	On
1pm – 2pm	70%	100%	70%	On
2pm – 3pm	70%	100%	70%	On
3pm – 4pm	70%	100%	70%	On
4pm – 5pm	70%	100%	70%	On
5pm – 6pm	60%	80%	70%	On
6pm – 7pm	60%	25%	70%	On
7pm – 8pm	50%	25%	70%	On
8pm – 9pm	50%	25%	70%	On
9pm – 10pm	50%	10%	70%	On
10pm – 11pm	50%	10%	70%	On
11pm – 12am	50%	10%	70%	On

Kitchen

The 'Kitchen' profile should be used for:

- Hospital kitchens

The profile assumes 16 hour operation, seven days per week.

Table 11: Kitchen

Time	Occupancy (%)	Artificial lighting (%)	Appliances and equipment (%)	Plant Operation
12am – 1am	0%	0%	10%	Off
1am – 2am	0%	0%	10%	Off
2am – 3am	0%	0%	10%	Off
3am – 4am	0%	0%	10%	Off
4am – 5am	0%	0%	10%	Off
5am – 6am	70%	100%	100%	On
6am – 7am	70%	100%	100%	On
7am – 8am	70%	100%	100%	On
8am – 9am	50%	50%	50%	On
9am – 10am	50%	50%	50%	On
10am – 11am	70%	100%	100%	On
11am – 12pm	70%	100%	100%	On
12pm – 1pm	70%	100%	100%	On
1pm – 2pm	50%	50%	50%	On
2pm – 3pm	50%	50%	50%	On
3pm – 4pm	70%	100%	100%	On
4pm – 5pm	70%	100%	100%	On
5pm – 6pm	60%	75%	75%	On
6pm – 7pm	50%	50%	50%	On
7pm – 8pm	50%	50%	50%	On
8pm – 9pm	50%	50%	50%	On
9pm – 10pm	0%	0%	10%	Off
10pm – 11pm	0%	0%	10%	Off
11pm – 12am	0%	0%	10%	Off

Transitory spaces – 12 hours

The 'Transitory spaces – 12 hours' profile should be used for:

- All spaces that are lit and have low transient occupancy during the day only.

This profile is expected to be used for corridors and stairways within healthcare facilities with daytime operation only.

Note: Waiting areas are not considered transitory spaces.

Table 12: Transitory spaces - 12 hours

Time	Occupancy (%)	Artificial lighting (%)	Appliances and equipment (%)	Plant Operation
12am – 1am	0%	10%	0%	Off
1am – 2am	0%	10%	0%	Off
2am – 3am	0%	10%	0%	Off
3am – 4am	0%	10%	0%	Off
4am – 5am	0%	10%	0%	Off
5am – 6am	0%	10%	0%	Off
6am – 7am	0%	10%	0%	Off
7am – 8am	0%	40%	0%	On
8am – 9am	0%	80%	0%	On
9am – 10am	0%	100%	0%	On
10am – 11am	0%	100%	0%	On
11am – 12pm	0%	100%	0%	On
12pm – 1pm	0%	100%	0%	On
1pm – 2pm	0%	100%	0%	On
2pm – 3pm	0%	100%	0%	On
3pm – 4pm	0%	100%	0%	On
4pm – 5pm	0%	100%	0%	On
5pm – 6pm	0%	80%	0%	On
6pm – 7pm	0%	60%	0%	On
7pm – 8pm	0%	40%	0%	Off
8pm – 9pm	0%	20%	0%	Off
9pm – 10pm	0%	10%	0%	Off
10pm – 11pm	0%	10%	0%	Off
11pm – 12am	0%	10%	0%	Off

Transitory spaces – 24 hours

The 'Transitory spaces – 24 hours' profile should be used for:

- All spaces that are lit and have low transient occupancy 24 hours per day, seven days per week.

This profile is expected to be used for corridors and stairways within a 24 hour hospital.

Note: Waiting areas are not considered transitory spaces.

Table 13: Transitory spaces - 24 hours

Time	Occupancy (%)	Artificial lighting (%)	Appliances and equipment (%)	Plant Operation
12am – 1am	0%	100%	0%	On
1am – 2am	0%	100%	0%	On
2am – 3am	0%	100%	0%	On
3am – 4am	0%	100%	0%	On
4am – 5am	0%	100%	0%	On
5am – 6am	0%	100%	0%	On
6am – 7am	0%	100%	0%	On
7am – 8am	0%	100%	0%	On
8am – 9am	0%	100%	0%	On
9am – 10am	0%	100%	0%	On
10am – 11am	0%	100%	0%	On
11am – 12pm	0%	100%	0%	On
12pm – 1pm	0%	100%	0%	On
1pm – 2pm	0%	100%	0%	On
2pm – 3pm	0%	100%	0%	On
3pm – 4pm	0%	100%	0%	On
4pm – 5pm	0%	100%	0%	On
5pm – 6pm	0%	100%	0%	On
6pm – 7pm	0%	100%	0%	On
7pm – 8pm	0%	100%	0%	On
8pm – 9pm	0%	100%	0%	On
9pm – 10pm	0%	100%	0%	On
10pm – 11pm	0%	100%	0%	On
11pm – 12am	0%	100%	0%	On

Back of house

The 'Back of house' profile should be used for:

- Back of house spaces which have very low transient occupancy and that are only lit during those periods of occupancy.

Examples of areas that would use this profile are engineering or maintenance services, mechanical services and materials management areas.

The 'Plant Operation' section of this profile should be used for conditioned back of house spaces. Otherwise, it is assumed that the space is unconditioned and plant operation is 'Off'. Regardless of the condition of the space, lighting is to be modelled as per this profile.

Table 14: Back of house

Time	Occupancy (%)	Artificial lighting (%)	Appliances and equipment (%)	Plant Operation
12am – 1am	0%	0%	10%	On
1am – 2am	0%	0%	10%	On
2am – 3am	0%	0%	10%	On
3am – 4am	0%	0%	10%	On
4am – 5am	0%	0%	10%	On
5am – 6am	0%	0%	10%	On
6am – 7am	0%	0%	10%	On
7am – 8am	0%	10%	15%	On
8am – 9am	0%	10%	70%	On
9am – 10am	0%	10%	100%	On
10am – 11am	0%	10%	100%	On
11am – 12pm	0%	10%	100%	On
12pm – 1pm	0%	10%	100%	On
1pm – 2pm	0%	10%	100%	On
2pm – 3pm	0%	10%	100%	On
3pm – 4pm	0%	10%	100%	On
4pm – 5pm	0%	10%	100%	On
5pm – 6pm	0%	10%	60%	On
6pm – 7pm	0%	10%	25%	On
7pm – 8pm	0%	0%	15%	On
8pm – 9pm	0%	0%	15%	On
9pm – 10pm	0%	0%	10%	On
10pm – 11pm	0%	0%	10%	On
11pm – 12am	0%	0%	10%	On

Appendix B – Lift energy consumption methodology

The formula which needs to be used to calculate the energy consumption by a lift per year, in kWh, is given below. This formula has been adapted for Green Star from the Draft ISO standard ISO/DIS 25745-1: Energy performance of lifts and escalators - Part 1: Energy measurement and conformance.

$$\text{Energy used by a lift per year (kWh)} = \frac{\text{Number of trips} \times \text{Average trip time (s)} \times \text{Average power load (kW)} + \text{Standby power (kW)} \times \text{Standby hours per day} \times \text{Standby days per year}}{3600}$$

This formula should be used for both the Proposed and Reference Building. The design team needs to establish the trip time, lift power rating and standby power for the Proposed Building (definitions below). All other parameters for the Proposed and all parameters for the Reference Building and are given in the table below.

Table 15: Definition of parameters used to calculate the energy consumption of a lift

Parameter	Definition	Proposed Building modelling requirements	Reference Building modelling requirements
Number of trips	The standard number of trips per year for the relevant building type	The number of trips for the Proposed Building should be taken from Table 16: Number of trips	As Proposed Building
Average trip time	The time, in seconds, for the lift to travel half the possible travel distance measured from doors closed to doors opening. The distance of average trip is $0.5 \times N$, where: N is the total travel distance (m) of the lift. The lift can be assumed to run at the rated speed (m/s) over the whole trip.	This parameter needs to be calculated by the design team. It will depend on the distance the lift will travel and the rated speed of the lift.	The distance travelled is the same as the Proposed Building. The rated speed of the Reference Building lift is 1m/s
Average power load	The average power load is assumed to be the lift motor power rating (kW)	From supplier specifications for lift being assessed. This figure can be reduced by 20% if the lift has regenerative breaks.	40kW
3600	The figure of 3600 converts the first half of the equation, which is in kW, into kWh.		
Standby power	The average power load is assumed to be the lift motor power rating (kW)	From supplier specifications for lift being assessed	0.15kW
Standby hours per day	Number of hours per day that the car lights and lift control systems are operating	24 hours unless the lift has a power off feature, in which case the figure used should be 18 hours.	24 hours
Standby days per year	Number of days the standby power is applicable	365 days Except for offices and education facilities, where if the lift has a power off feature, 260 days should be used. Shopping centres and hospitals should use 365 days in all cases.	365 days

Table 16: Number of trips

Lift Duty	Trips per day	Building types (lift operation days/week)	Trips per year		
			5 days/ week (260 days/ year)	6 days/ week (312 days/ year)	7 days/ week (365 days/ year)
Low	100	residential care (7), goods (5), library (6), entertainment centres (7)	26,000	31,200	36,500
Medium	300	office car parks (5), general car parks (7), residential (7), university (5), hotels (7), low rise hospitals (7), shopping centres (7)	78,000		109,500
High	750	office (5), airports (7), high rise hospitals (7)	195,000		273,750
Intensive	1000	HQ office (5)	260,000		365,000

Gina Barney (2007)

APPENDIX C – GREENHOUSE GAS EMISSIONS FACTORS

Greenhouse gas emissions factors quantify the amount of greenhouse gas which will be emitted into the atmosphere, as a result of using one unit of energy, i.e. the amount of greenhouse gas emitted due to using one kilowatt hour of electricity or one megajoule of gas, coal or bio-fuel.

The greenhouse gas emission factors used in the Green Star – Healthcare Greenhouse Gas Emissions Calculator are from the Australian Government’s National Greenhouse Accounts (NGA) Factors Workbook, current at the date of release.

Notes on the emissions factors used:

1. **The greenhouse gas emissions factors used include all direct and indirect emissions** (or Scopes 1, 2 and 3). Direct emissions include all greenhouse gases emitted directly from the site from the combustion of fuels. An example of a direct emission would be the emissions from a gas boiler or gas cook top. Indirect emissions include all emissions which occur off-site, but which result from the building’s demand for energy. For example, indirect emissions include the emissions which occur at electricity power stations in order to supply the building with electricity, and the emissions which occur due to the extraction, transportation and fugitive losses of fuels, which the building or power station will ultimately consume.
2. **The emissions factors are given in terms of kilograms of carbon dioxide ‘equivalent’** (kg/CO₂-e per unit of energy). This is because the emissions factor not only accounts for emissions from carbon dioxide, but from other significant greenhouse gases (which occur due to the combustion of fossil and bio-fuels) such as methane and nitrous oxide.
3. **Emissions factors for electricity and gas vary between states and territories.** For electricity, this is due to the mix of fuels used in the power stations. For gas, this is due to the variation in the fugitive emissions from the gas distribution network.
4. **The Scope 3 emissions factor for gas is the emissions factor for ‘small users’.** Small users are defined as a user that consumes less than 100,000 gigajoules per year

Table 17: Greenhouse Gas Emissions Factors for all states and territories in Australia from National Greenhouse Accounts (NGA) Factors Workbook (DCC, 2008)

State	Electricity (kgCO ₂ -e /kWh)	Gas (kgCO ₂ -e /MJ)	LPG (kgCO ₂ -e / MJ)	Diesel (kgCO ₂ -e / MJ)	Coal (kgCO ₂ -e / MJ)	Solid Biomass (kgCO ₂ -e / MJ)	Liquid Biofuels (kgCO ₂ -e / MJ)
ACT	1.06	0.0661	0.0652	0.0748	0.0930	0.0018	0.0003
NSW	1.06	0.0661					
NT	0.80	0.0570					
QLD	1.04	0.0573					
SA	0.98	0.0707					
TAS*	0.80	0.0570					
VIC	1.31	0.0572					
WA	0.98	0.0589					

* The emissions factors used for Tasmania in the Green Star – Healthcare v1 Greenhouse Gas Emissions Calculator Guide are the lowest emissions from mainland Australia, which at this time are the emissions factors from the Northern Territories. This ensures that initiatives such as renewable energy and low carbon technologies are rewarded in Tasmania.